



TYPICAL NOTES:

- 1)-ALL EXPOSED PIPING AND FITTINGS TO BE GALVANIZED WITH EXCEPTION OF STORZ CONNECTION
- 2)-40' MAX. FROM FDC TO APPARATUS ACCESS LOCATION
- 3)-FOR NFPA 13R SYSTEMS (2 1/2" RISER AND SMALLER) SINGLE. FDC W/ RALEIGH THREADS (3.340 X 6 SHARPE V FORM)
- 4)-WHEN BUILDING HT. IS GREATER THAN 200' USE RAL. SIAMESE

CITY OF RALEIGH FIRE DEPARTMENT
 FIRE PROTECTION DIVISION
 310 WEST MARTIN ST. RALEIGH, NC 27602

DESCRIPTION:
 FLUSH FDC DETAIL REQUIRMENTS

REVISIONS:
 5-1-06
 W Warren

DATE:
 S B

DRAWING NO.
 FP-14