



**\*\* New detail for valve installation**

- NOTES:**
1. ONLY MANUFACTURED VALVE BOX EXTENSIONS SHALL BE ALLOWED.
  2. VALVE OPERATING NUT MUST BE EXTENDED SO THAT THE DEPTH IS NO GREATER THAN 5' (ft.) FROM THE SURFACE USING A MANUFACTURER APPROVED EXTENSION KIT.
  3. PRECAST CONCRETE ENCASUREMENT IS ALLOWED OUTSIDE OF PAVED AREAS.

CITY OF RALEIGH			
DEPARTMENT OF PUBLIC UTILITIES			
<b>RECLAIMED WATER VALVE AND BOX INSTALLATION</b>			
DWG. NO.	REVISIONS:	DATE:	REVISIONS:
R-14	DHL	10/1/07	