



NOTE:
 TAPS MADE ON EXISTING PVC SHALL
 BE MADE USING A TAPPING SADDLE.
 TAPS MADE ON DUCTILE IRON CAN BE
 EITHER DIRECT OR WITH A TAPPING
 SADDLE.

SIZE "F"(I.D.) (SERVICE TAP SIZE FROM MAIN)	NUMBER OF METERED SERVICES ALLOWED	
	3/4"	1"
2"	9-16	5-8
1 1/2"	5-8	4
1"	4	2
3/4"	2	N/A

SEE DETAIL FOR STANDARD
 WATER SERVICE INSTALLATION
 W-23

CITY OF RALEIGH				
DEPARTMENT OF PUBLIC UTILITIES				
STANDARD GANG METER ASSEMBLY				
DWG. NO.	REVISIONS	DATE	REVISIONS	DATE
W-26	METERED SERV.	4-1-82	D.W.C.	11-18-99
	Y.C.A.	12-31-91	J.P.S.	11-4-10